

Technical drawing of a rectangular frame structure, likely a mold or a frame for a material sample. The drawing includes the following details:

- Dimensions:** The overall width is 1000 mm (indicated by a dimension line at the top and bottom). The overall height is 600 mm (indicated by a dimension line on the right side).
- Material:** The frame is made of "Drut stalowy, ocynkowany DFeZn Ø8" (Galvanized steel wire, DFeZn Ø8).
- Connections:** The corners are connected using "Złącze krzyżowe skręcane" (Twisted cross connections).
- Internal Structure:** The frame is divided into a grid of 4x4 squares by dashed lines. The internal dimensions of the grid are 800 mm by 500 mm.
- Labels:** The grid is labeled with "M.1" and "M.2" at various points, indicating specific measurement or material locations. The text "DLA KAWY POGRĄŻENIA DO MONITOROWANIA" (FOR COFFEE INFUSION MONITORING) is visible on the right side.
- Electrical Symbols:** There are electrical symbols at the corners, including a battery symbol and a resistor symbol labeled $R \leq 10 \Omega$.
- Other Labels:** "Uziomienie" (Grounding) is written at the bottom right. "4-5%" is written near the bottom right corner.

DLA KAŻDEGO ZWODU WYKONAĆ PIONOWE UZIOMY POPRZEC
POGRĄŻANIE W ZIEMI PRĘTÓW POŁĄCZONYCH ZE SOBĄ
DO MOMENTU OSIĄGNIĘCIA WYMAGANEJ REZYSTANCJI

 $R \leq 10\Omega$

Zwód pionowy układany w rurze ochronnej
odgromowej w warstwie ocieplenia

ziom pionowy pograżony w podłożu

 <h1>SYSTEMY BEZPIECZEŃSTWA</h1> <p>Paweł Dzięgielewski</p> <p>ul. Toruńska 73/4, 87-800 Włocławek</p>			
<p>OBIEKT</p> <p>BUDYNEK ŹRÓDEŁ ZASILANIA W GAZY MEDYCZNE DLA ODDZIAŁÓW SZPITALA SPZOZ W KRASNYMSTAWIE</p> <p>Dz. nr: 3019/13 obręb Krasnystaw Miasto 22-300 Krasnystaw, ul. M.Sobieskiego 4</p>			
<p>INWESTOR</p> <p>SPZOZ w Krasnymstawie</p> <p>ul. Sobieskiego 4, 22-300 Krasnystaw</p>			
<p>STADIUM</p> <p>PROJEKT BUDOWLANY</p>			
<p>NAZWA RYSUNKU</p> <p>Schemat instalacji odgromowej</p>			
<p>PROJEKTANT</p> <p>mgr inż. Marek Wojciechowski</p> <p>KUP/0085/PWOE/12</p>		<p>PODPIS</p>	
<p>SPRAWDZAJĄCY</p> <p>mgr inż. Czesław Szymaniak</p> <p>KUP/0144/POOE/12</p>		<p>PODPIS</p>	
<p>OPRACOWAŁ</p> <p>inż. Paweł Dzięgielewski</p>		<p>PODPIS</p>	
<p>SKALA</p> <p>1:50</p>	<p>DATA</p> <p>20.11.2017 r.</p>	<p>NR RYS.</p> <p>3</p>	<p>NR STR</p> <p>29</p>